

Bio Clean Downspout Filter - Removal Efficiencies

Numeric Reductions (mg/L)

Location	Coarse Total Suspended Solids mg/L			Fine Total Suspended Solids mg/L			Total Petroleum Hydrocarbons mg/L		
	Inlet	Outlet	Removal Efficiency	Inlet	Outlet	Removal Efficiency	Inlet	Outlet	Removal Efficiency
Waves Environmental			93%			58%	223	30	87%

Bio Clean Flume Filter Pollutant Removal Testing - 2007