



*half way of the internal length of the stormwater treatment system.*

*The nutrient separating screen system shall start at the inflow pipe not more than 4" from the wall of the inflow pipe.*

*17. The stormwater treatment system must have two separate reports verifying no scouring occurs at flows equal to or greater than the specified treatment flow rate for that particle size distribution.*

*18. The stormwater treatment system shall have a shallow sump, not more than 48" from invert of outflow pipe to bottom floor of the sump area.*

*19. The stormwater treatment system must have a minimum of two sediment chambers (sump areas) which are separated by a vertical pier that divides the chamber from the bottom of the sump to the invert of the outflow pipe. No openings are allowed at the bottom or coming up vertically along the pier. Or any other method that would connect the two chambers together such as orifices.*